



Approval ID:
241890

EQUIPMENT TYPE APPROVAL

Distribution Customer Use

We hereby confirm that below detailed Equipment is in compliance with the latest relevant regulations and standards, therefore it is **Approved** to be used in Distribution Customer Installation for five years, where expiry date is due the Approval Holder shall apply for renewal if needed.

Approval Details	
Approval ID: <i>241890</i>	Approval Holder: <i>Future Power Switchgear Co. W.L.L.</i>
Approval Type: <i>Distribution Customer Use</i>	Valid Till: <i>06/20/2029</i>
Equipment Details	
Category: <i>LV Switchgears</i>	Trademark: <i>Geya</i>
Description: <i>Annexure-A</i>	Designation: <i>Annexure-A</i>
Manufacturer Details	
Name: <i>Zhejiang Geya Electrical Co. Ltd.</i>	Country of Origin: <i>China</i>

Comments:

EDD Requirements Fulfilled

Signature:

06/27/2024 06:55 AM

Osama Al Zayed

Act. Director, Electricity Distribution

Validation:



This approval is signed electronically, validation of the approval can be confirmed through scanning the QR Code or visiting EWA Official Website.

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
4. The Approval Holder is responsible to present the approval in full without any omissions upon request.
5. The Approval Holder is responsible to ensure that an approved Equipment is manufactured, tested, and delivered in accordance with the latest relevant regulation and standards.
6. The Installation Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.
7. The Installation Contractor is responsible to validate the approval using above referenced QR Code.



Approval ID:
241890

ANNEXURE-A

ID	Description	Designation
241890-1	MCCB 20A 18kA	GYCM3-125S
241890-2	MCCB 20A 30kA	GYCM3-125H
241890-3	MCCB 32A 18kA	GYCM3-125S
241890-4	MCCB 32A 30kA	GYCM3-125H
241890-5	MCCB 40A 18kA	GYCM3-125S
241890-6	MCCB 40A 30kA	GYCM3-125H
241890-7	MCCB 50A 18kA	GYCM3-125S
241890-8	MCCB 50A 30kA	GYCM3-125H
241890-9	MCCB 63A 18kA	GYCM3-125S
241890-10	MCCB 63A 30kA	GYCM3-125H
241890-11	MCCB 80A 18kA	GYCM3-125S
241890-12	MCCB 80A 30kA	GYCM3-125H
241890-13	MCCB 100A 18kA	GYCM3-125S
241890-14	MCCB 100A 30kA	GYCM3-125H
241890-15	MCCB 125A 18kA	GYCM3-125S
241890-16	MCCB 125A 30kA	GYCM3-125H
241890-17	MCCB 20A 35kA	GYCM3-160S
241890-18	MCCB 20A 70kA	GYCM3-160H
241890-19	MCCB 32A 35kA	GYCM3-160S
241890-20	MCCB 32A 70kA	GYCM3-160H
241890-21	MCCB40A 35kA	GYCM3-160S
241890-22	MCCB 40A 70kA	GYCM3-160H
241890-23	MCCB 50A 35kA	GYCM3-160S
241890-24	MCCB50A 70kA	GYCM3-160H
241890-25	MCCB 63A 35kA	GYCM3-160S
241890-26	MCCB 63A 70kA	GYCM3-160H
241890-27	MCCB 80A 35kA	GYCM3-160S
241890-28	MCCB 80A 70kA	GYCM3-160H
241890-29	MCCB100A 35kA	GYCM3-160S
241890-30	MCCB 100A 70kA	GYCM3-160H
241890-31	MCCB 125A 35kA	GYCM3-160S
241890-32	MCCB 125A 70kA	GYCM3-160H
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
4. The Approval Holder is responsible to present the approval in full without any omissions upon request.
5. The Approval Holder is responsible to ensure that an approved Equipment is manufactured, tested, and delivered in accordance with the latest relevant regulation and standards.
6. The MTC Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.
7. The MTC Contractor is responsible to validate the approval using above referenced QR Code.