



Approval ID:
241903

EQUIPMENT TYPE APPROVAL

Distribution Customer Use

We hereby confirm that below detailed Equipment is in compliance with the latest relevant regulations and standards, therefore it is **Approved** to be used in Distribution Customer Installation for five years, where expiry date is due the Approval Holder shall apply for renewal if needed.

Approval Details	
Approval ID: <i>241903</i>	Approval Holder: <i>Future Power Switchgear Co. W.L.L.</i>
Approval Type: <i>Distribution Customer Use</i>	Valid Till: <i>06/20/2029</i>
Equipment Details	
Category: <i>LV Switchgears</i>	Trademark: <i>Geya</i>
Description: <i>Annexure-A</i>	Designation: <i>Annexure-A</i>
Manufacturer Details	
Name: <i>Zhejiang Geya Electrical Co. Ltd.</i>	Country of Origin: <i>China</i>

Comments:

EDD Requirements Fulfilled

Signature:

06/27/2024 06:57 AM

Osama Al Zayed

Act. Director, Electricity Distribution

Validation:



This approval is signed electronically, validation of the approval can be confirmed through scanning the QR Code or visiting EWA Official Website.

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
4. The Approval Holder is responsible to present the approval in full without any omissions upon request.
5. The Approval Holder is responsible to ensure that an approved Equipment is manufactured, tested, and delivered in accordance with the latest relevant regulation and standards.
6. The Installation Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.
7. The Installation Contractor is responsible to validate the approval using above referenced QR Code.



Approval ID:
241903

ANNEXURE-A

ID	Description	Designation
241903-1	MCCB 160A 35kA	GYCM3-160S
241903-2	MCCB 160A 70kA	GYCM3-160H
241903-3	MCCB 100A 35kA	GYCM3-315S
241903-4	MCCB 100A 70kA	GYCM3-315H
241903-5	MCCB 125A 35kA	GYCM3-315S
241903-6	MCCB 125A 70kA	GYCM3-315H
241903-7	MCCB 160A 35kA	GYCM3-315S
241903-8	MCCB 160A 70kA	GYCM3-315H
241903-9	MCCB 200A 35kA	GYCM3-315S
241903-10	MCCB 200A 70kA	GYCM3-315H
241903-11	MCCB 250A 35kA	GYCM3-315S
241903-12	MCCB 250A 70kA	GYCM3-315H
241903-13	MCCB 315A 35kA	GYCM3-315S
241903-14	MCCB 315A 70kA	GYCM3-315H
241903-15	MCCB 250A 50kA	GYCM3-630S
241903-16	MCCB 250A 70kA	GYCM3-630H
241903-17	MCCB 315A 50kA	GYCM3-630S
241903-18	MCCB 315A 70kA	GYCM3-630H
241903-19	MCCB 400A 50kA	GYCM3-630S
241903-20	MCCB 400A 70kA	GYCM3-630H
241903-21	MCCB 500A 50kA	GYCM3-630S
241903-22	MCCB 500A 70kA	GYCM3-630H
241903-23	MCCB 630A 50kA	GYCM3-630S
241903-24	MCCB 630A 70kA	GYCM3-630H
241903-25	MCCB 500A 50kA	GYCM3-800S
241903-26	MCCB 500A 70kA	GYCM3-800H
241903-27	MCCB 630A 50kA	GYCM3-800S
241903-28	MCCB 630A 70kA	GYCM3-800H
241903-29	MCCB 700A 50kA	GYCM3-800S
241903-30	MCCB 700A 70kA	GYCM3-800H
241903-31	MCCB 800A 50kA	GYCM3-800S
241903-32	MCCB 800A 70kA	GYCM3-800H
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
4. The Approval Holder is responsible to present the approval in full without any omissions upon request.
5. The Approval Holder is responsible to ensure that an approved Equipment is manufactured, tested, and delivered in accordance with the latest relevant regulation and standards.
6. The MTC Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.
7. The MTC Contractor is responsible to validate the approval using above referenced QR Code.