



Approval ID:  
**241913**

## EQUIPMENT TYPE APPROVAL

### Distribution Customer Use

We hereby confirm that below detailed Equipment is in compliance with the latest relevant regulations and standards, therefore it is **Approved** to be used in Distribution Customer Installation for five years, where expiry date is due the Approval Holder shall apply for renewal if needed.

Approval Details	
Approval ID: <i>241913</i>	Approval Holder: <i>Future Power Switchgear Co. W.L.L.</i>
Approval Type: <i>Distribution Customer Use</i>	Valid Till: <i>06/27/2029</i>
Equipment Details	
Category: <i>LV Switchgears</i>	Trademark: <i>GEYA</i>
Description: <i>Annexure-A</i>	Designation: <i>Annexure-A</i>
Manufacturer Details	
Name: <i>Zhejiang Geya Electrical Co LTD</i>	Country of Origin: <i>China</i>

#### Comments:

*EDD Requirements Fulfilled*

#### Signature:

06/27/2024 01:29 PM

**Osama Al Zayed**

**Act. Director, Electricity Distribution**

#### Validation:



This approval is signed electronically, validation of the approval can be confirmed through scanning the QR Code or visiting EWA Official Website.

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
4. The Approval Holder is responsible to present the approval in full without any omissions upon request.
5. The Approval Holder is responsible to ensure that an approved Equipment is manufactured, tested, and delivered in accordance with the latest relevant regulation and standards.
6. The Installation Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.
7. The Installation Contractor is responsible to validate the approval using above referenced QR Code.



Approval ID:  
**241913**

## ANNEXURE-A

ID	Description	Designation
241913-1	16A 2P 30mA Residual Current Circuit Breaker (RCCB)	GYL9 6A 2P 30mA
241913-2	16A 2P 300mA Residual Current Circuit Breaker (RCCB)	GYL9 16A 2P 300mA
241913-3	25A 2P 30mA Residual Current Circuit Breaker (RCCB)	GYL9 25A 2P 30mA
241913-4	25A 2P 300mA Residual Current Circuit Breaker (RCCB)	GYL9 25A 2P 300mA
241913-5	32A 2P 30mA Residual Current Circuit Breaker (RCCB)	GYL9 32A 2P 30mA
241913-6	32A 2P 300mA Residual Current Circuit Breaker (RCCB)	GYL9 32A 2P 300mA
241913-7	40A 2P 30mA Residual Current Circuit Breaker (RCCB)	GYL9 40A 2P 30mA
241913-8	40A 2P 300mA Residual Current Circuit Breaker (RCCB)	GYL9 40A 2P 300mA
241913-9	50A 2P 30mA Residual Current Circuit Breaker (RCCB)	GYL9 50A 2P 30mA
241913-10	50A 2P 300mA Residual Current Circuit Breaker (RCCB)	GYL9 50A 2P 300mA
241913-11	63A 2P 30mA Residual Current Circuit Breaker (RCCB)	GYL9 63A 2P 30mA
241913-12	63A 2P 300mA Residual Current Circuit Breaker (RCCB)	GYL9 63A 2P 300mA
241913-13	80A 2P 30mA Residual Current Circuit Breaker (RCCB)	GYL9 80A 2P 30mA
241913-14	80A 2P 300mA Residual Current Circuit Breaker (RCCB)	GYL9 80A 2P 300mA
241913-15	100A 2P 30mA Residual Current Circuit Breaker (RCCB)	GYL9 100A 2P 30mA
241913-16	100A 2P 300mA Residual Current Circuit Breaker (RCCB)	GYL9 100A 2P 300mA
241913-17	16A 4P 30mA Residual Current Circuit Breaker (RCCB)	GYL9 16A 4P 30mA
241913-18	16A 4P 300mA Residual Current Circuit Breaker (RCCB)	GYL9 16A 4P 300mA
241913-19	25A 4P 30mA Residual Current Circuit Breaker (RCCB)	GYL9 25A 4P 30mA
241913-20	25A 4P 300mA Residual Current Circuit Breaker (RCCB)	GYL9 25A 4P 300mA
241913-21	32A 4P 30mA Residual Current Circuit Breaker (RCCB)	GYL9 32A 4P 30mA
241913-22	32A 4P 300mA Residual Current Circuit Breaker (RCCB)	GYL9 32A 4P 300mA
241913-23	40A 4P 30mA Residual Current Circuit Breaker (RCCB)	GYL9 40A 4P 30mA
241913-24	40A 4P 300mA Residual Current Circuit Breaker (RCCB)	GYL9 40A 4P 300mA
241913-25	50A 4P 30mA Residual Current Circuit Breaker (RCCB)	GYL9 50A 4P 30mA
241913-26	50A 4P 300mA Residual Current Circuit Breaker (RCCB)	GYL9 50A 4P 300mA
241913-27	63A 4P 30mA Residual Current Circuit Breaker (RCCB)	GYL9 63A 4P 30mA
241913-28	63A 4P 300mA Residual Current Circuit Breaker (RCCB)	GYL9 63A 4P 300mA
241913-29	80A 4P 30mA Residual Current Circuit Breaker (RCCB)	GYL9 80A 4P 30mA
241913-30	80A 4P 300mA Residual Current Circuit Breaker (RCCB)	GYL9 80A 4P 300mA
241913-31	100A 4P 30mA Residual Current Circuit Breaker (RCCB)	GYL9 100A 4P 30mA
241913-32	100A 4P 300mA Residual Current Circuit Breaker (RCCB)	GYL9 100A 4P 300mA
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
4. The Approval Holder is responsible to present the approval in full without any omissions upon request.
5. The Approval Holder is responsible to ensure that an approved Equipment is manufactured, tested, and delivered in accordance with the latest relevant regulation and standards.
6. The MTC Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.
7. The MTC Contractor is responsible to validate the approval using above referenced QR Code.