



EQUIPMENT TYPE APPROVAL

Distribution Customer Use

We hereby confirm that below detailed Equipment is in compliance with the latest relevant regulations and standards, therefore it is **Approved** to be used in Distribution Customer Installation for five years, where expiry date is due the Approval Holder shall apply for renewal if needed.

Approval Details		
Approval ID: 241973	Approval Holder: Everest Electrical W.L.L.	
Approval Type: Distribution Customer Use	Valid Till: 07/24/2029	
Equipment Details		
Category: Cable Management System	Trademark: Decoduct	
Description: Annexure-A	Designation: Annexure-A	
Manufacturer Details		
Name: Interplast Co Limited	Country of Origin: <i>United Arab Emirates</i>	

Comments:

EDD Requirements Fulfilled



Validation:



This approval is signed electronically, validation of the approval can be confirmed through scanning the QR Code or visiting EWA Official Website.

- 1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
- 2. The Directorate retains the right to publish a censored copy of the approval.
- 3. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
- 4. The Approval Holder is responsible to present the approval in full without any omissions upon request.
- 5. The Approval Holder is responsible to ensure that an approved Equipment is manufactured, tested, and delivered in accordance with the latest relevant regulation and standards.
- 6. The Installation Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.
- 7. The Installation Contractor is responsible to validate the approval using above referenced QR Code.





Approval ID: **241973**

ANNEXURE-A

ID	Description	Designation
241973-1	20mm Light Grade Round Conduit 320N	DCL2
241973-2	25mm Light Grade Round Conduit 320N	DCL3
241973-3	32mm Light Grade Round Conduit 320N	DCL4
241973-4	38mm Light Grade Round Conduit 320N	DCL5
241973-5	50mm Light Grade Round Conduit 320N	DCL6
241973-6	20mm Medium Grade Round Conduit 750N	DCH2
241973-7	25mm Medium Grade Round Conduit 750N	DCH3
241973-8	32mm Medium Grade Round Conduit 750N	DCH4
241973-9	38mm Medium Grade Round Conduit 750N	DCH5
241973-10	50mm Medium Grade Round Conduit 750N	DCH6
241973-11	20mm Heavy Grade Round Conduit 1250N	DCV2
241973-12	25mm Heavy Grade Round Conduit 1250N	DCV3
241973-13	32mm Heavy Grade Round Conduit 1250N	DCV4
241973-14	38mm Heavy Grade Round Conduit 1250N	DCV5
241973-15	50mm Heavy Grade Round Conduit 1250N	DCV6
241973-16	20mm Super Heavy Grade Round Conduit 1400N	DSV2
241973-17	25mm Super Heavy Grade Round Conduit 1400N	DSV3
241973-18	32mm Super Heavy Grade Round Conduit 2000N	DSV4
241973-19	38mm Super Heavy Grade Round Conduit 2000N	DSV5
241973-20	50mm Super Heavy Grade Round Conduit 3000N	DSV6
241973-21	20mm Heavy Gauge Pliable Conduit	DPH2
241973-22	25mm Heavy Gauge Pliable Conduit	DPH3
241973-23	20mm Light Gauge Pliable Conduit	DPL2
241973-24	25mm Light Gauge Pliable Conduit	DPL3
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-

^{1.} The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.

^{2.} The Directorate retains the right to publish a censored copy of the approval.

^{3.} The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.

^{4.} The Approval Holder is responsible to present the approval in full without any omissions upon request.

^{5.} The Approval Holder is responsible to ensure that an approved Equipment is manufactured, tested, and delivered in accordance with the latest relevant regulation and standards.

^{6.} The MTC Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.

^{7.} The MTC Contractor is responsible to validate the approval using above referenced QR Code.