



Approval ID:
242386

EQUIPMENT TYPE APPROVAL

Distribution Customer Use

We hereby confirm that below detailed Equipment is in compliance with the latest relevant regulations and standards, therefore it is **Approved** to be used in Distribution Customer Installation for five years, where expiry date is due the Approval Holder shall apply for renewal if needed.

Approval Details	
Approval ID: <i>242386</i>	Approval Holder: <i>Bahrain Switchgear & Lighting Industries W.L.L.</i>
Approval Type: <i>Distribution Customer Use</i>	Valid Till: <i>11/28/2029</i>
Equipment Details	
Category: <i>LV Switchgears</i>	Trademark: <i>ETI</i>
Description: <i>Annexure-A</i>	Designation: <i>Annexure-A</i>
Manufacturer Details	
Name: <i>ETI Elektroelement d.o.o.</i>	Country of Origin: <i>Slovenia</i>

Comments:

EDD Requirements Fulfilled

Signature:



11/28/2024 11:42 AM

Ebrahim Khalil Ebrahim
Director, Electricity Distribution

Validation:



This approval is signed electronically, validation of the approval can be confirmed through scanning the QR Code or visiting EWA Official Website.

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
4. The Approval Holder is responsible to present the approval in full without any omissions upon request.
5. The Approval Holder is responsible to ensure that an approved Equipment is manufactured, tested, and delivered in accordance with the latest relevant regulation and standards.
6. The Installation Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.
7. The Installation Contractor is responsible to validate the approval using above referenced QR Code.



Approval ID:
242386

ANNEXURE-A

ID	Description	Designation
242386-1	Residual Current Operated Circuit-Breakers 16A 2P 30mA	EFI - P2, 16A
242386-2	Residual Current Operated Circuit-Breakers 16A 2P 300mA	EFI - P2, 16A
242386-3	Residual Current Operated Circuit-Breakers 16A 2P 500mA	EFI - P2, 16A
242386-4	Residual Current Operated Circuit-Breakers 25A 2P 30mA	EFI - P2, 25A
242386-5	Residual Current Operated Circuit-Breakers 25A 2P 300mA	EFI - P2, 25A
242386-6	Residual Current Operated Circuit-Breakers 25A 2P 500mA	EFI - P2, 25A
242386-7	Residual Current Operated Circuit-Breakers 32A 2P 30mA	EFI - P2, 32A
242386-8	Residual Current Operated Circuit-Breakers 32A 2P 300mA	EFI - P2, 32A
242386-9	Residual Current Operated Circuit-Breakers 32A 2P 500mA	EFI - P2, 32A
242386-10	Residual Current Operated Circuit-Breakers 40A 2P 30mA	EFI - P2, 40A
242386-11	Residual Current Operated Circuit-Breakers 40A 2P 300mA	EFI - P2, 40A
242386-12	Residual Current Operated Circuit-Breakers 40A 2P 500mA	EFI - P2, 40A
242386-13	Residual Current Operated Circuit-Breakers 63A 2P 30mA	EFI - P2, 63A
242386-14	Residual Current Operated Circuit-Breakers 63A 2P 300mA	EFI - P2, 63A
242386-15	Residual Current Operated Circuit-Breakers 63A 2P 500mA	EFI - P2, 63A
242386-16	Residual Current Operated Circuit-Breakers 80A 2P 30mA	EFI - P2, 80A
242386-17	Residual Current Operated Circuit-Breakers 80A 2P 300mA	EFI - P2, 80A
242386-18	Residual Current Operated Circuit-Breakers 80A 2P 500mA	EFI - P2, 80A
242386-19	Residual Current Operated Circuit-Breakers 16A 4P 30mA	EFI - P4, 16A
242386-20	Residual Current Operated Circuit-Breakers 16A 4P 300mA	EFI - P4, 16A
242386-21	Residual Current Operated Circuit-Breakers 16A 4P 500mA	EFI - P4, 16A
242386-22	Residual Current Operated Circuit-Breakers 25A 4P 30mA	EFI - P4, 25A
242386-23	Residual Current Operated Circuit-Breakers 25A 4P 300mA	EFI - P4, 25A
242386-24	Residual Current Operated Circuit-Breakers 25A 4P 500mA	EFI - P4, 25A
242386-25	Residual Current Operated Circuit-Breakers 32A 4P 30mA	EFI - P4, 32A
242386-26	Residual Current Operated Circuit-Breakers 32A 4P 300mA	EFI - P4, 32A
242386-27	Residual Current Operated Circuit-Breakers 32A 4P 500mA	EFI - P4, 32A
242386-28	Residual Current Operated Circuit-Breakers 40A 4P 30mA	EFI - P4, 40A
242386-29	Residual Current Operated Circuit-Breakers 40A 4P 300mA	EFI - P4, 40A
242386-30	Residual Current Operated Circuit-Breakers 40A 4P 500mA	EFI - P4, 40A
242386-31	Residual Current Operated Circuit-Breakers 63A 4P 30mA	EFI - P4, 63A
242386-32	Residual Current Operated Circuit-Breakers 63A 4P 300mA	EFI - P4, 63A
242386-33	Residual Current Operated Circuit-Breakers 63A 4P 500mA	EFI - P4, 63A
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
4. The Approval Holder is responsible to present the approval in full without any omissions upon request.
5. The Approval Holder is responsible to ensure that an approved Equipment is manufactured, tested, and delivered in accordance with the latest relevant regulation and standards.
6. The MTC Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.
7. The MTC Contractor is responsible to validate the approval using above referenced QR Code.