



Approval ID:  
**242473**

## EQUIPMENT TYPE APPROVAL

### Distribution Customer Use

We hereby confirm that below detailed Equipment is in compliance with the latest relevant regulations and standards, therefore it is **Approved** to be used in Distribution Customer Installation for five years, where expiry date is due the Approval Holder shall apply for renewal if needed.

Approval Details	
Approval ID: <i>242473</i>	Approval Holder: <i>Bahrain Switchgear &amp; Lighting Industries W.L.L.</i>
Approval Type: <i>Distribution Customer Use</i>	Valid Till: <i>12/30/2029</i>
Equipment Details	
Category: <i>LV Switchgears</i>	Trademark: <i>ETI</i>
Description: <i>Annexure-A</i>	Designation: <i>Annexure-A</i>
Manufacturer Details	
Name: <i>ETI, d.o.o.</i>	Country of Origin: <i>Slovenia</i>

#### Comments:

*EDD Requirements Fulfilled*

#### Signature:

  


12/30/2024 02:42 PM

**Ebrahim Khalil Ebrahim**

**Director, Electricity Distribution**

#### Validation:



This approval is signed electronically, validation of the approval can be confirmed through scanning the QR Code or visiting EWA Official Website.

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
4. The Approval Holder is responsible to present the approval in full without any omissions upon request.
5. The Approval Holder is responsible to ensure that an approved Equipment is manufactured, tested, and delivered in accordance with the latest relevant regulation and standards.
6. The Installation Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.
7. The Installation Contractor is responsible to validate the approval using above referenced QR Code.



Approval ID:  
**242473**

## ANNEXURE-A

ID	Description	Designation
242473-1	6A, 1P, 10KA, Characteristic B MCB	ETIMAT P10, 001901007
242473-2	10A, 1P, 10KA, Characteristic B MCB	ETIMAT P10, 001901008
242473-3	13A, 1P, 10KA, Characteristic B MCB	ETIMAT P10, 001901009
242473-4	16A, 1P, 10KA, Characteristic B MCB	ETIMAT P10, 001901010
242473-5	0.5A, 1P, 10KA, Characteristic C MCB	ETIMAT P10, 001901021
242473-6	1A, 1P, 10KA, Characteristic C MCB	ETIMAT P10, 001901022
242473-7	1.6A, 1P, 10KA, Characteristic C MCB	ETIMAT P10, 001901023
242473-8	2A, 1P, 10KA, Characteristic C MCB	ETIMAT P10, 001901024
242473-9	3A, 1P, 10KA, Characteristic C MCB	ETIMAT P10, 001901025
242473-10	4A, 1P, 10KA, Characteristic C MCB	ETIMAT P10, 001901026
242473-11	6A, 1P, 10KA, Characteristic C MCB	ETIMAT P10, 001901027
242473-12	10A, 1P, 10KA, Characteristic C MCB	ETIMAT P10, 001901028
242473-13	13A, 1P, 10KA, Characteristic C MCB	ETIMAT P10, 001901029
242473-14	16A, 1P, 10KA, Characteristic C MCB	ETIMAT P10, 001901030
242473-15	1A, 1+NP, 10KA, Characteristic B MCB	ETIMAT P10, 001901102
242473-16	1.6A, 1+NP, 10KA, Characteristic B MCB	ETIMAT P10, 001901103
242473-17	2A, 1+NP, 10KA, Characteristic B MCB	ETIMAT P10, 001901104
242473-18	3A, 1+NP, 10KA, Characteristic B MCB	ETIMAT P10, 001901105
242473-19	4A, 1+NP, 10KA, Characteristic B MCB	ETIMAT P10, 001901106
242473-20	6A, 1+NP, 10KA, Characteristic B MCB	ETIMAT P10, 001901107
242473-21	10A, 1+NP, 10KA, Characteristic B MCB	ETIMAT P10, 001901108
242473-22	13A, 1+NP, 10KA, Characteristic B MCB	ETIMAT P10, 001901109
242473-23	16A, 1+NP, 10KA, Characteristic B MCB	ETIMAT P10, 001901110
242473-24	0.5A, 1+NP, 10KA, Characteristic C MCB	ETIMAT P10, 001901121
242473-25	1A, 1+NP, 10KA, Characteristic C MCB	ETIMAT P10, 001901122
242473-26	1.6A, 1+NP, 10KA, Characteristic C MCB	ETIMAT P10, 001901123
242473-27	2A, 1+NP, 10KA, Characteristic C MCB	ETIMAT P10, 001901124
242473-28	3A, 1+NP, 10KA, Characteristic C MCB	ETIMAT P10, 001901125
242473-29	4A, 1+NP, 10KA, Characteristic C MCB	ETIMAT P10, 001901126
242473-30	6A, 1+NP, 10KA, Characteristic C MCB	ETIMAT P10, 001901127
242473-31	10A, 1+NP, 10KA, Characteristic C MCB	ETIMAT P10, 001901128
242473-32	13A, 1+NP, 10KA, Characteristic C MCB	ETIMAT P10, 001901129
242473-33	16A, 1+NP, 10KA, Characteristic C MCB	ETIMAT P10, 001901130
242473-34	1A, 2P, 10KA, Characteristic B MCB	ETIMAT P10, 001901202
242473-35	1.6A, 2P, 10KA, Characteristic B MCB	ETIMAT P10, 001901203
242473-36	2A, 2P, 10KA, Characteristic B MCB	ETIMAT P10, 001901204
242473-37	3A, 2P, 10KA, Characteristic B MCB	ETIMAT P10, 001901205
242473-38	4A, 2P, 10KA, Characteristic B MCB	ETIMAT P10, 001901206
242473-39	6A, 2P, 10KA, Characteristic B MCB	ETIMAT P10, 001901207
242473-40	10A, 2P, 10KA, Characteristic B MCB	ETIMAT P10, 001901208

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
4. The Approval Holder is responsible to present the approval in full without any omissions upon request.
5. The Approval Holder is responsible to ensure that an approved Equipment is manufactured, tested, and delivered in accordance with the latest relevant regulation and standards.
6. The MTC Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.
7. The MTC Contractor is responsible to validate the approval using above referenced QR Code.